



Date Submitted: 6/24/2010

Water Use Efficiency Annual Performance Report - 2009

WS Name: WHITE SALMON, CITY OF

Water System ID# : 96350 WS County: KLICKITAT

Report submitted by: *Tommy Smith*

Meter Installation Information:

Estimate the percentage of metered connections: Yes

If not 100% metered – Did you submit a meter installation plan to DOH? No

Within your meter installation plan, what date did you commit to completing meter installation?

Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period 01/01/2009 To 12/31/2009

Incomplete or missing data for the year? No

If yes, explain:

Total Water Produced & Purchased (TP) – Annual volume gallons	237,000,000 gallons
Authorized Consumption (AC) – Annual Volume in gallons	181,746,000 gallons
Distribution System Leakage – Annual Volume TP – AC	55,254,000 gallons
Distribution System Leakage – DSL = [(TP – AC) / TP] x 100 %	23.3 %
3-year annual average - %	17.0 % 2007, 2008, 2009

Goal-Setting Information:

Enter the date of most recent public forum to establish WUE goal: 05/21/2008

Has goal been changed since last performance report? No

Note: Customer goal must be re-established every 6 years through a public process.

Customer WUE Goal (Demand Side):

To reduce outside water use and reduce leakage (toilets, faucets, irrigation lines) Reduce leakage within the city system. Reduce water consumption by 10 percent over the next 20-year period.

Customer (Demand Side) Goal Progress:

Mandatory odd and even sprinkling ordinance adopted. Annual water use reduced from 1030 acre-feet in 2005 to 730 acre feet in 2009.

Additional Information Regarding Supply and Demand Side WUE Efforts

The City did a full leak analysis in 2005 and fixed any leakage discovered. The basic results of the leak survey was that the system was in good shape. During the years 2004 through 2007, the City installed or rebuilt all residential water meters. In 2008, monthly reading began, with 12 reads per year instead of 4. Completed removal of pump control discharge valve, saving 300,000 gallons per month by January 2010. Budget authorization for 425 radio read meters to be installed in 2010 (Phase II of III). Meter bench testing program underway.

Describe Progress in Reaching Goals:

- Estimate how much water you saved.
- Report progress toward meeting goals within your established timeframe.
- Identify any WUE measures you are currently implementing.
- If you established a goal to maintain a historic level (such as maintaining daily consumption at 65 gallons per person per day for the next two years) you must explain why you are unable to reduce water use below that level.

The following questions will help DOH better understand water usage, water resources management and drought response. The data will be used to provide technical assistance, not for regulatory purposes.

All questions are voluntary

Month	Date of Measurement	Static Water Level (feet below measuring point)	Dynamic Water Level (feet below measuring point)
January			
February			
March			
April			
May			
June			
July			
August			
September			
October			
November			
December			

Water level data:

Please provide the following information (if known) to help us better utilize the water level data.

Well tag Id number:

Well depth:

Water level accuracy (within 0.01 ft < 1 ft ~ 1 ft)

Completion type (e.g., cased open interval, cased open-ended, cased open-ended with perforations, etc...)

Location coordinates (latitude, longitude) and accuracy of the coordinates (< 1ft, ~1ft, >1000ft)

Water level parameter name (e.g. depth below measuring point, depth below top of casing, depth below ground surface)

Elevation of top of casing OR elevation of measuring point if different than top of casing (as specified in question 7)

Monthly/Seasonal Water Usage:

What was your maximum daily water demand for the previous year (in gallons per day)? _____

Month	Volume of Water Produced in gallons
January	
February	
March	
April	
May	
June	
July	
August	
September	
October	
November	
December	

Water shortage response:

Did you activate any level of water shortage response plan the previous year?

- Yes No There was no need to

If you activated a water shortage response plan the previous year, what level did you activate? (Check all that apply)

- Advisory Conservation Voluntary Conservation
 Mandatory Conservation Rationing Other

What factors caused your water shortage the previous year?

- Drought Fire Landslides Earthquakes
 Flooding Water Supply Limitations Other

Do not mail, fax, or email this report to DOH